



## NORTH BURNETT REGIONAL COUNCIL 2021 - 2022 ANNUAL SWIM REPORTING

North Burnett Regional Council is required by the Department of Natural Resources, Mines and Energy to submit annual data for water and sewerage key performance indicators. Results presented on the table below were reported through the SWIM Reporting System for the period 1 July 2021 to 30 June 2022. The below results give a general overview of the water and sewerage

POTABLE WATER INDICATORS			
SCHEME	INDICATOR TITLE	VALUE	UNITS
Biggenden Water	Number water treatment plants: providing full treatment	1	Count
Biggenden Water	Length water mains	11.9	km
Biggenden Water	Capacity of water treatment plants	1	ML/day
Biggenden Water	Total potable water storage volume	2.185	ML
Biggenden Water	Volume water lost: potable water	15.2	ML
Biggenden Water	Water main breaks per 100 km water main	0	per 100 km water main
Biggenden Water	Water service complaints per 1000 connections	0	per 1000 connections
Biggenden Water	Water and sewerage billing and account complaints per 1000 connections	2.3	per 1000 connections
Biggenden Water	Water and sewerage complaints (all) per 1000 connections	2.3	per 1000 connections
Biggenden Water	Average frequency unplanned interruptions: water	0	per 1000 connections
Biggenden Water	Connected residential properties: water	0.373	000s
Biggenden Water	Connected non-residential properties: water	0.064	000s
Biggenden Water	Percent CSS response target met: water incidents	100	%
Biggenden Water	Water quality complaints per 1000 connections	0	per 1000 connections
Biggenden Water	Fixed charge: water value	651	\$/annum
Biggenden Water	Fixed charge: water description	Per Connection	Text
Biggenden Water	Volume water sourced: surface water	0	ML
Biggenden Water	Volume water sourced: groundwater	99.5	ML
Biggenden Water	Maximum daily demand	0.9	ML/day
Biggenden Water	Volume all water imported: internal and external	NR	ML
Biggenden Water	Volume all water exported: internal and external	0	ML
Biggenden Water	Volume potable water produced at a water treatment plant	94.9	ML
Biggenden Water	Volume potable water supplied: residential	59.4	ML
Biggenden Water	Volume potable water supplied: non-residential	19.8	ML
Biggenden Water	Volume water sourced: desalination marine water	NR	ML
Biggenden Water	Volume water sourced: all	99.5	ML
Biggenden Water	Water restriction duration: PWCM	254	days
Biggenden Water	Water restriction duration: Level 1	111	days
Biggenden Water	Water restriction duration: Level 2	NR	days
Biggenden Water	Water restriction duration: Level 3	NR	days
Biggenden Water	Water restriction duration: Level 4	NR	days
Biggenden Water	Water restriction duration: Level 5	NR	days
Biggenden Water	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no
Biggenden Water	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no
Biggenden Water	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no
Biggenden Water	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no
Biggenden Water	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	yes	yes/no
Biggenden Water	Months water supply remaining as at 30 June (KPI level)	4	1,2,3,4,5,6
Biggenden Water	Confidence water demand will be met: next 18 mths	high	high,fair,unsure,low,very low
Biggenden Water	Confidence water demand will be met: next 5 yrs	fair	high,fair,unsure,low,very low
Biggenden Water	Available contingency supplies	yes	yes/no

SEWERAGE INDICATORS			
SCHEME	INDICATOR TITLE	VALUE	UNITS
Biggenden Sewerage	Sewerage mains breaks/chokes per 100 km sewer main	0	per 100 km sewer mains
Biggenden Sewerage	Number sewage treatment plants	1	Count
Biggenden Sewerage	Length sewerage mains and channels	14.8	km
Biggenden Sewerage	Sewerage service complaints per 1000 connections	2.4	per 1000 connections
Biggenden Sewerage	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections
Biggenden Sewerage	Water and sewerage complaints (all) per 1000 connections	2.4	per 1000 connections
Biggenden Sewerage	Connected residential properties: sewerage	0.359	000s
Biggenden Sewerage	Percent CSS response target met: sewerage incidents	100	%
Biggenden Sewerage	Connected non-residential properties: sewerage	0.059	000s
Biggenden Sewerage	Fixed charge: sewerage value	634	\$/annum
Biggenden Sewerage	Fixed charge: sewerage description	First Pedestal	Text

EFFLUENT REUSE			
SCHEME	INDICATOR TITLE	VALUE	UNITS
Biggenden Effluent Re-use	Length water mains	0.1	km
Biggenden Effluent Re-use	Water main breaks per 100 km water main	0	per 100 km water main
Biggenden Effluent Re-use	Water service complaints per 1000 connections	0	per 1000 connections
Biggenden Effluent Re-use	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections
Biggenden Effluent Re-use	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections
Biggenden Effluent Re-use	Connected residential properties: water	NR	000s
Biggenden Effluent Re-use	Connected non-residential properties: water	0.001	000s
Biggenden Effluent Re-use	Water quality complaints per 1000 connections	0	per 1000 connections
Biggenden Effluent Re-use	Fixed charge: water value	0	\$/annum
Biggenden Effluent Re-use	Fixed charge: water description	NR	Text
Biggenden Effluent Re-use	Volume all water imported: internal and external	NR	ML
Biggenden Effluent Re-use	Volume all water exported: internal and external	NR	ML
Biggenden Effluent Re-use	Volume recycled sewage supplied: all	0.6	ML
Biggenden Effluent Re-use	Volume water sourced: all	0.6	ML

POTABLE WATER INDICATORS			
SCHEME	INDICATOR TITLE	VALUE	UNITS
Eidsvold Water	Number water treatment plants: providing full treatment	1	Count
Eidsvold Water	Length water mains	27.1	km
Eidsvold Water	Capacity of water treatment plants	1.24	ML/day
Eidsvold Water	Total potable water storage volume	1.3	ML
Eidsvold Water	Volume water lost: potable water	13.5	ML
Eidsvold Water	Water main breaks per 100 km water main	7.4	per 100 km water main
Eidsvold Water	Water service complaints per 1000 connections	0	per 1000 connections
Eidsvold Water	Water and sewerage billing and account complaints per 1000 connections	3.1	per 1000 connections
Eidsvold Water	Water and sewerage complaints (all) per 1000 connections	12.3	per 1000 connections
Eidsvold Water	Average frequency unplanned interruptions: water	24.6	per 1000 connections
Eidsvold Water	Connected residential properties: water	0.255	000s
Eidsvold Water	Connected non-residential properties: water	0.07	000s
Eidsvold Water	Percent CSS response target met: water incidents	100	%
Eidsvold Water	Water quality complaints per 1000 connections	9.2	per 1000 connections
Eidsvold Water	Fixed charge: water value	651	\$/annum
Eidsvold Water	Fixed charge: water description	Per Connection	Text
Eidsvold Water	Volume water sourced: surface water	NR	ML
Eidsvold Water	Volume water sourced: groundwater	143.4	ML
Eidsvold Water	Maximum daily demand	0.7	ML/day
Eidsvold Water	Volume all water imported: internal and external	NR	ML
Eidsvold Water	Volume all water exported: internal and external	0	ML
Eidsvold Water	Volume potable water produced at a water treatment plant	127	ML
Eidsvold Water	Volume potable water supplied: residential	73.4	ML
Eidsvold Water	Volume potable water supplied: non-residential	39.5	ML
Eidsvold Water	Volume water sourced: desalination marine water	NR	ML
Eidsvold Water	Volume water sourced: all	143	ML
Eidsvold Water	Water restriction duration: PWCM	254	days
Eidsvold Water	Water restriction duration: Level 1	NR	days
Eidsvold Water	Water restriction duration: Level 2	NR	days
Eidsvold Water	Water restriction duration: Level 3	NR	days
Eidsvold Water	Water restriction duration: Level 4	NR	days
Eidsvold Water	Water restriction duration: Level 5	NR	days
Eidsvold Water	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no
Eidsvold Water	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no
Eidsvold Water	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no
Eidsvold Water	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no
Eidsvold Water	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	yes	yes/no
Eidsvold Water	Months water supply remaining as at 30 June (KPI level)	5	1,2,3,4,5,6
Eidsvold Water	Confidence water demand will be met: next 18 mths	high	high,fair,unsure,low,very low
Eidsvold Water	Confidence water demand will be met: next 5 yrs	high	high,fair,unsure,low,very low
Eidsvold Water	Available contingency supplies	yes	yes/no

SEWERAGE INDICATORS			
SCHEME	INDICATOR TITLE	VALUE	UNITS
Eidsvold Sewerage	Sewerage mains breaks/chokes per 100 km sewer main	0	per 100 km sewer mains
Eidsvold Sewerage	Number sewage treatment plants	1	Count
Eidsvold Sewerage	Length sewerage mains and channels	11	km
Eidsvold Sewerage	Sewerage service complaints per 1000 connections	0	per 1000 connections
Eidsvold Sewerage	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections
Eidsvold Sewerage	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections
Eidsvold Sewerage	Connected residential properties: sewerage	0.188	000s
Eidsvold Sewerage	Percent CSS response target met: sewerage incidents	100	%
Eidsvold Sewerage	Connected non-residential properties: sewerage	0.052	000s
Eidsvold Sewerage	Fixed charge: sewerage value	634	\$/annum
Eidsvold Sewerage	Fixed charge: sewerage description	First Pedestal	Text

POTABLE WATER INDICATORS			
SCHEME	INDICATOR TITLE	VALUE	UNITS
Gayndah Water	Number water treatment plants: providing full treatment	1	Count
Gayndah Water	Length water mains	27.7	km
Gayndah Water	Capacity of water treatment plants	4	ML/day
Gayndah Water	Total potable water storage volume	3.6	ML
Gayndah Water	Volume water lost: potable water	85.1	ML
Gayndah Water	Water main breaks per 100 km water main	14.4	per 100 km water main
Gayndah Water	Water service complaints per 1000 connections	4.9	per 1000 connections
Gayndah Water	Water and sewerage billing and account complaints per 1000 connections	1	per 1000 connections
Gayndah Water	Water and sewerage complaints (all) per 1000 connections	6.8	per 1000 connections
Gayndah Water	Average frequency unplanned interruptions: water	19.5	per 1000 connections
Gayndah Water	Connected residential properties: water	0.878	000s
Gayndah Water	Connected non-residential properties: water	0.15	000s
Gayndah Water	Percent CSS response target met: water incidents	100	%
Gayndah Water	Water quality complaints per 1000 connections	1	per 1000 connections
Gayndah Water	Fixed charge: water value	651	\$/annum
Gayndah Water	Fixed charge: water description	Per Connection	Text
Gayndah Water	Volume water sourced: surface water	432.3	ML
Gayndah Water	Volume water sourced: groundwater	NR	ML
Gayndah Water	Maximum daily demand	2.3	ML/day
Gayndah Water	Volume all water imported: internal and external	NR	ML
Gayndah Water	Volume all water exported: internal and external	5.2	ML
Gayndah Water	Volume potable water produced at a water treatment plant	395.9	ML
Gayndah Water	Volume potable water supplied: residential	200.7	ML
Gayndah Water	Volume potable water supplied: non-residential	108.1	ML
Gayndah Water	Volume water sourced: desalination marine water	NR	ML
Gayndah Water	Volume water sourced: all	432.3	ML
Gayndah Water	Water restriction duration: PWCM	254	days
Gayndah Water	Water restriction duration: Level 1	NR	days
Gayndah Water	Water restriction duration: Level 2	NR	days
Gayndah Water	Water restriction duration: Level 3	NR	days
Gayndah Water	Water restriction duration: Level 4	NR	days
Gayndah Water	Water restriction duration: Level 5	NR	days
Gayndah Water	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no
Gayndah Water	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no
Gayndah Water	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no
Gayndah Water	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no
Gayndah Water	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	yes	yes/no
Gayndah Water	Months water supply remaining as at 30 June (KPI level)	5	1,2,3,4,5,6
Gayndah Water	Confidence water demand will be met: next 18 mths	high	high,fair,unsure,low,very low
Gayndah Water	Confidence water demand will be met: next 5 yrs	high	high,fair,unsure,low,very low
Gayndah Water	Available contingency supplies	yes	yes/no

SEWERAGE INDICATORS			
SCHEME	INDICATOR TITLE	VALUE	UNITS
Gayndah Sewerage	Sewerage mains breaks/chokes per 100 km sewer main	0	per 100 km sewer mains
Gayndah Sewerage	Number sewage treatment plants	1	Count
Gayndah Sewerage	Length sewerage mains and channels	32.3	km
Gayndah Sewerage	Sewerage service complaints per 1000 connections	1.2	per 1000 connections
Gayndah Sewerage	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections
Gayndah Sewerage	Water and sewerage complaints (all) per 1000 connections	1.2	per 1000 connections
Gayndah Sewerage	Connected residential properties: sewerage	0.736	000s
Gayndah Sewerage	Percent CSS response target met: sewerage incidents	100	%
Gayndah Sewerage	Connected non-residential properties: sewerage	0.133	000s
Gayndah Sewerage	Fixed charge: sewerage value	634	\$/annum
Gayndah Sewerage	Fixed charge: sewerage description	First Pedestal	Text

EFFLUENT REUSE			
SCHEME	INDICATOR TITLE	VALUE	UNITS
Gayndah Effluent Re-use	Length water mains	0.5	km
Gayndah Effluent Re-use	Water main breaks per 100 km water main	0	per 100 km water main
Gayndah Effluent Re-use	Water service complaints per 1000 connections	0	per 1000 connections
Gayndah Effluent Re-use	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections
Gayndah Effluent Re-use	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections
Gayndah Effluent Re-use	Connected residential properties: water	NR	000s
Gayndah Effluent Re-use	Connected non-residential properties: water	0.001	000s
Gayndah Effluent Re-use	Water quality complaints per 1000 connections	0	per 1000 connections
Gayndah Effluent Re-use	Fixed charge: water value	0	\$/annum
Gayndah Effluent Re-use	Fixed charge: water description	NR	Text
Gayndah Effluent Re-use	Volume all water imported: internal and external	NR	ML
Gayndah Effluent Re-use	Volume all water exported: internal and external	NR	ML
Gayndah Effluent Re-use	Volume recycled sewage supplied: all	25.7	ML
Gayndah Effluent Re-use	Volume water sourced: all	25.7	ML

POTABLE WATER INDICATORS			
SCHEME	INDICATOR TITLE	VALUE	UNITS
Mingo Crossing Water	Number water treatment plants: providing full treatment	1	Count
Mingo Crossing Water	Length water mains	0	km
Mingo Crossing Water	Capacity of water treatment plants	0.03	ML/day
Mingo Crossing Water	Total potable water storage volume	0.088	ML
Mingo Crossing Water	Volume water lost: potable water	0.1	ML
Mingo Crossing Water	Water main breaks per 100 km water main	0	per 100 km water main
Mingo Crossing Water	Water service complaints per 1000 connections	0	per 1000 connections
Mingo Crossing Water	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections
Mingo Crossing Water	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections
Mingo Crossing Water	Average frequency unplanned interruptions: water	0	per 1000 connections
Mingo Crossing Water	Connected residential properties: water	0.001	000s
Mingo Crossing Water	Connected non-residential properties: water	0.001	000s
Mingo Crossing Water	Percent CSS response target met: water incidents	100	%
Mingo Crossing Water	Water quality complaints per 1000 connections	0	per 1000 connections
Mingo Crossing Water	Fixed charge: water value	NR	\$/annum
Mingo Crossing Water	Fixed charge: water description	NR	Text
Mingo Crossing Water	Volume water sourced: surface water	0	ML
Mingo Crossing Water	Volume water sourced: groundwater	NR	ML
Mingo Crossing Water	Maximum daily demand	0	ML/day
Mingo Crossing Water	Volume all water imported: internal and external	0.9	ML
Mingo Crossing Water	Volume all water exported: internal and external	0	ML
Mingo Crossing Water	Volume potable water produced at a water treatment plant	0.8	ML
Mingo Crossing Water	Volume potable water supplied: residential	0	ML
Mingo Crossing Water	Volume potable water supplied: non-residential	0.7	ML
Mingo Crossing Water	Volume water sourced: desalination marine water	NR	ML
Mingo Crossing Water	Volume water sourced: all	0.9	ML
Mingo Crossing Water	Water restriction duration: PWCM	254	days
Mingo Crossing Water	Water restriction duration: Level 1	NR	days
Mingo Crossing Water	Water restriction duration: Level 2	NR	days
Mingo Crossing Water	Water restriction duration: Level 3	NR	days
Mingo Crossing Water	Water restriction duration: Level 4	NR	days
Mingo Crossing Water	Water restriction duration: Level 5	NR	days
Mingo Crossing Water	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no
Mingo Crossing Water	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no
Mingo Crossing Water	Has water demand forecasts been developed or reviewed in the last 5 yrs?	no	yes/no
Mingo Crossing Water	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no
Mingo Crossing Water	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	yes	yes/no
Mingo Crossing Water	Months water supply remaining as at 30 June (KPI level)	5	1,2,3,4,5,6
Mingo Crossing Water	Confidence water demand will be met: next 18 mths	fair	high,fair,unsure,low,very low
Mingo Crossing Water	Confidence water demand will be met: next 5 yrs	fair	high,fair,unsure,low,very low
Mingo Crossing Water	Available contingency supplies	yes	yes/no

SEWERAGE INDICATORS			
SCHEME	INDICATOR TITLE	VALUE	UNITS
Mingo Crossing Sewerage	Sewerage mains breaks/chokes per 100 km sewer main	0	per 100 km sewer mains
Mingo Crossing Sewerage	Number sewage treatment plants	1	Count
Mingo Crossing Sewerage	Length sewerage mains and channels	0.8	km
Mingo Crossing Sewerage	Sewerage service complaints per 1000 connections	0	per 1000 connections
Mingo Crossing Sewerage	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections
Mingo Crossing Sewerage	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections
Mingo Crossing Sewerage	Connected residential properties: sewerage	0.001	000s
Mingo Crossing Sewerage	Percent CSS response target met: sewerage incidents	100	%
Mingo Crossing Sewerage	Connected non-residential properties: sewerage	0.001	000s
Mingo Crossing Sewerage	Fixed charge: sewerage value	NR	\$/annum
Mingo Crossing Sewerage	Fixed charge: sewerage description	NR	Text

POTABLE WATER INDICATORS			
SCHEME	INDICATOR TITLE	VALUE	UNITS
Monto Water	Number water treatment plants: providing full treatment	0	Count
Monto Water	Length water mains	28.7	km
Monto Water	Capacity of water treatment plants	NR	ML/day
Monto Water	Total potable water storage volume	3.3	ML
Monto Water	Volume water lost: potable water	22.7	ML
Monto Water	Water main breaks per 100 km water main	13.9	per 100 km water main
Monto Water	Water service complaints per 1000 connections	0	per 1000 connections
Monto Water	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections
Monto Water	Water and sewerage complaints (all) per 1000 connections	2.7	per 1000 connections
Monto Water	Average frequency unplanned interruptions: water	27.2	per 1000 connections
Monto Water	Connected residential properties: water	0.621	000s
Monto Water	Connected non-residential properties: water	0.115	000s
Monto Water	Percent CSS response target met: water incidents	100	%
Monto Water	Water quality complaints per 1000 connections	2.7	per 1000 connections
Monto Water	Fixed charge: water value	651	\$/annum
Monto Water	Fixed charge: water description	Per Connection	Text
Monto Water	Volume water sourced: surface water	NR	ML
Monto Water	Volume water sourced: groundwater	222.7	ML
Monto Water	Maximum daily demand	1.5	ML/day
Monto Water	Volume all water imported: internal and external	NR	ML
Monto Water	Volume all water exported: internal and external	0	ML
Monto Water	Volume potable water produced at a water treatment plant	212.3	ML
Monto Water	Volume potable water supplied: residential	150.7	ML
Monto Water	Volume potable water supplied: non-residential	37.8	ML
Monto Water	Volume water sourced: desalination marine water	NR	ML
Monto Water	Volume water sourced: all	222.7	ML
Monto Water	Water restriction duration: PWCM	254	days
Monto Water	Water restriction duration: Level 1	NR	days
Monto Water	Water restriction duration: Level 2	NR	days
Monto Water	Water restriction duration: Level 3	NR	days
Monto Water	Water restriction duration: Level 4	NR	days
Monto Water	Water restriction duration: Level 5	NR	days
Monto Water	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no
Monto Water	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no
Monto Water	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no
Monto Water	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no
Monto Water	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	yes	yes/no
Monto Water	Months water supply remaining as at 30 June (KPI level)	5	1,2,3,4,5,6
Monto Water	Confidence water demand will be met: next 18 mths	high	high,fair,unsure,low,very low
Monto Water	Confidence water demand will be met: next 5 yrs	high	high,fair,unsure,low,very low
Monto Water	Available contingency supplies	yes	yes/no

SEWERAGE INDICATORS			
SCHEME	INDICATOR TITLE	VALUE	UNITS
Monto Sewerage	Sewerage mains breaks/chokes per 100 km sewer main	0	per 100 km sewer mains
Monto Sewerage	Number sewage treatment plants	1	Count
Monto Sewerage	Length sewerage mains and channels	21.8	km
Monto Sewerage	Sewerage service complaints per 1000 connections	6.1	per 1000 connections
Monto Sewerage	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections
Monto Sewerage	Water and sewerage complaints (all) per 1000 connections	6.1	per 1000 connections
Monto Sewerage	Connected residential properties: sewerage	0.563	000s
Monto Sewerage	Percent CSS response target met: sewerage incidents	100	%
Monto Sewerage	Connected non-residential properties: sewerage	0.096	000s
Monto Sewerage	Fixed charge: sewerage value	634	\$/annum
Monto Sewerage	Fixed charge: sewerage description	First Pedestal	Text

EFFLUENT REUSE			
SCHEME	INDICATOR TITLE	VALUE	UNITS
Monto Effluent Re-use	Length water mains	1.5	km
Monto Effluent Re-use	Water main breaks per 100 km water main	0	per 100 km water main
Monto Effluent Re-use	Water service complaints per 1000 connections	0	per 1000 connections
Monto Effluent Re-use	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections
Monto Effluent Re-use	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections
Monto Effluent Re-use	Connected residential properties: water	NR	000s
Monto Effluent Re-use	Connected non-residential properties: water	0.001	000s
Monto Effluent Re-use	Water quality complaints per 1000 connections	0	per 1000 connections
Monto Effluent Re-use	Fixed charge: water value	0	\$/annum
Monto Effluent Re-use	Fixed charge: water description	NR	Text
Monto Effluent Re-use	Volume all water imported: internal and external	NR	ML
Monto Effluent Re-use	Volume all water exported: internal and external	NR	ML
Monto Effluent Re-use	Volume recycled sewage supplied: all	24.6	ML
Monto Effluent Re-use	Volume water sourced: all	24.6	ML

POTABLE WATER INDICATORS			
SCHEME	INDICATOR TITLE	VALUE	UNITS
Mount Perry Water	Number water treatment plants: providing full treatment	0	Count
Mount Perry Water	Length water mains	15.8	km
Mount Perry Water	Capacity of water treatment plants	NR	ML/day
Mount Perry Water	Total potable water storage volume	0.6	ML
Mount Perry Water	Volume water lost: potable water	6	ML
Mount Perry Water	Water main breaks per 100 km water main	0	per 100 km water main
Mount Perry Water	Water service complaints per 1000 connections	8.9	per 1000 connections
Mount Perry Water	Water and sewerage billing and account complaints per 1000 connections	13.4	per 1000 connections
Mount Perry Water	Water and sewerage complaints (all) per 1000 connections	31.3	per 1000 connections
Mount Perry Water	Average frequency unplanned interruptions: water	0	per 1000 connections
Mount Perry Water	Connected residential properties: water	0.202	000s
Mount Perry Water	Connected non-residential properties: water	0.022	000s
Mount Perry Water	Percent CSS response target met: water incidents	100	%
Mount Perry Water	Water quality complaints per 1000 connections	8.9	per 1000 connections
Mount Perry Water	Fixed charge: water value	651	\$/annum
Mount Perry Water	Fixed charge: water description	Per Connection	Text
Mount Perry Water	Volume water sourced: surface water	NR	ML
Mount Perry Water	Volume water sourced: groundwater	43.6	ML
Mount Perry Water	Maximum daily demand	0.9	ML/day
Mount Perry Water	Volume all water imported: internal and external	NR	ML
Mount Perry Water	Volume all water exported: internal and external	3.6	ML
Mount Perry Water	Volume potable water produced at a water treatment plant	43.3	ML
Mount Perry Water	Volume potable water supplied: residential	31.5	ML
Mount Perry Water	Volume potable water supplied: non-residential	5.5	ML
Mount Perry Water	Volume water sourced: desalination marine water	NR	ML
Mount Perry Water	Volume water sourced: all	43.6	ML
Mount Perry Water	Water restriction duration: PWCM	254	days
Mount Perry Water	Water restriction duration: Level 1	111	days
Mount Perry Water	Water restriction duration: Level 2	NR	days
Mount Perry Water	Water restriction duration: Level 3	NR	days
Mount Perry Water	Water restriction duration: Level 4	NR	days
Mount Perry Water	Water restriction duration: Level 5	NR	days
Mount Perry Water	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no
Mount Perry Water	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no
Mount Perry Water	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no
Mount Perry Water	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no
Mount Perry Water	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	yes	yes/no
Mount Perry Water	Months water supply remaining as at 30 June (KPI level)	4	1,2,3,4,5,6
Mount Perry Water	Confidence water demand will be met: next 18 mths	high	high,fair,unsure,low,very low
Mount Perry Water	Confidence water demand will be met: next 5 yrs	unsure	high,fair,unsure,low,very low
Mount Perry Water	Available contingency supplies	yes	yes/no

SEWERAGE INDICATORS			
SCHEME	INDICATOR TITLE	VALUE	UNITS
Mount Perry Sewerage	Sewerage mains breaks/chokes per 100 km sewer main	0	per 100 km sewer mains
Mount Perry Sewerage	Number sewage treatment plants	1	Count
Mount Perry Sewerage	Length sewerage mains and channels	0.5	km
Mount Perry Sewerage	Sewerage service complaints per 1000 connections	0	per 1000 connections
Mount Perry Sewerage	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections
Mount Perry Sewerage	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections
Mount Perry Sewerage	Connected residential properties: sewerage	0	000s
Mount Perry Sewerage	Percent CSS response target met: sewerage incidents	100	%
Mount Perry Sewerage	Connected non-residential properties: sewerage	0.002	000s
Mount Perry Sewerage	Fixed charge: sewerage value	NR	\$/annum
Mount Perry Sewerage	Fixed charge: sewerage description	NR	Text

POTABLE WATER INDICATORS			
SCHEME	INDICATOR TITLE	VALUE	UNITS
Mundubbera Water	Number water treatment plants: providing full treatment	1	Count
Mundubbera Water	Length water mains	18.1	km
Mundubbera Water	Capacity of water treatment plants	2.6	ML/day
Mundubbera Water	Total potable water storage volume	4	ML
Mundubbera Water	Volume water lost: potable water	35.5	ML
Mundubbera Water	Water main breaks per 100 km water main	33.1	per 100 km water main
Mundubbera Water	Water service complaints per 1000 connections	0	per 1000 connections
Mundubbera Water	Water and sewerage billing and account complaints per 1000 connections	1.8	per 1000 connections
Mundubbera Water	Water and sewerage complaints (all) per 1000 connections	1.8	per 1000 connections
Mundubbera Water	Average frequency unplanned interruptions: water	17.6	per 1000 connections
Mundubbera Water	Connected residential properties: water	0.47	000s
Mundubbera Water	Connected non-residential properties: water	0.097	000s
Mundubbera Water	Percent CSS response target met: water incidents	100	%
Mundubbera Water	Water quality complaints per 1000 connections	0	per 1000 connections
Mundubbera Water	Fixed charge: water value	651	\$/annum
Mundubbera Water	Fixed charge: water description	Per Connection	Text
Mundubbera Water	Volume water sourced: surface water	254.2	ML
Mundubbera Water	Volume water sourced: ground water	NR	ML
Mundubbera Water	Maximum daily demand	1.4	ML/day
Mundubbera Water	Volume all water imported: internal and external	NR	ML
Mundubbera Water	Volume all water exported: internal and external	0	ML
Mundubbera Water	Volume potable water produced at a water treatment plant	229.2	ML
Mundubbera Water	Volume potable water supplied: residential	125.1	ML
Mundubbera Water	Volume potable water supplied: non-residential	67.4	ML
Mundubbera Water	Volume water sourced: desalination marine water	NR	ML
Mundubbera Water	Volume water sourced: all	254.2	ML
Mundubbera Water	Water restriction duration: PWCM	254	days
Mundubbera Water	Water restriction duration: Level 1	NR	days
Mundubbera Water	Water restriction duration: Level 2	NR	days
Mundubbera Water	Water restriction duration: Level 3	NR	days
Mundubbera Water	Water restriction duration: Level 4	NR	days
Mundubbera Water	Water restriction duration: Level 5	NR	days
Mundubbera Water	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no
Mundubbera Water	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no
Mundubbera Water	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no
Mundubbera Water	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no
Mundubbera Water	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	yes	yes/no
Mundubbera Water	Months water supply remaining as at 30 June (KPI level)	5	1,2,3,4,5,6
Mundubbera Water	Confidence water demand will be met: next 18 mths	high	high,fair,unsure,low,very low
Mundubbera Water	Confidence water demand will be met: next 5 yrs	high	high,fair,unsure,low,very low
Mundubbera Water	Available contingency supplies	yes	yes/no

SEWERAGE INDICATORS			
SCHEME	INDICATOR TITLE	VALUE	UNITS
Mundubbera Sewerage	Sewerage mains breaks/chokes per 100 km sewer main	43.3	per 100 km sewer mains
Mundubbera Sewerage	Number sewage treatment plants	1	Count
Mundubbera Sewerage	Length sewerage mains and channels	16.2	km
Mundubbera Sewerage	Sewerage service complaints per 1000 connections	3.6	per 1000 connections
Mundubbera Sewerage	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections
Mundubbera Sewerage	Water and sewerage complaints (all) per 1000 connections	3.6	per 1000 connections
Mundubbera Sewerage	Connected residential properties: sewerage	0.445	000s
Mundubbera Sewerage	Percent CSS response target met: sewerage incidents	100	%
Mundubbera Sewerage	Connected non-residential properties: sewerage	0.103	000s
Mundubbera Sewerage	Fixed charge: sewerage value	634	\$/annum
Mundubbera Sewerage	Fixed charge: sewerage description	First Pedestal	Text

EFFLUENT REUSE			
SCHEME	INDICATOR TITLE	VALUE	UNITS
Mundubbera Effluent Re-use	Length water mains	1.4	km
Mundubbera Effluent Re-use	Water main breaks per 100 km water main	0	per 100 km water main
Mundubbera Effluent Re-use	Water service complaints per 1000 connections	0	per 1000 connections
Mundubbera Effluent Re-use	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections
Mundubbera Effluent Re-use	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections
Mundubbera Effluent Re-use	Connected residential properties: water	NR	000s
Mundubbera Effluent Re-use	Connected non-residential properties: water	0.001	000s
Mundubbera Effluent Re-use	Water quality complaints per 1000 connections	0	per 1000 connections
Mundubbera Effluent Re-use	Fixed charge: water value	0	\$/annum
Mundubbera Effluent Re-use	Fixed charge: water description	NR	Text
Mundubbera Effluent Re-use	Volume all water imported: internal and external	NR	ML
Mundubbera Effluent Re-use	Volume all water exported: internal and external	NR	ML
Mundubbera Effluent Re-use	Volume recycled sewage supplied: all	60.1	ML
Mundubbera Effluent Re-use	Volume water sourced: all	60.1	ML

POTABLE WATER INDICATORS			
SCHEME	INDICATOR TITLE	VALUE	UNITS
Mulgildie Water	Number water treatment plants: providing full treatment	1	Count
Mulgildie Water	Length water mains	2.4	km
Mulgildie Water	Capacity of water treatment plants	0.2	ML/day
Mulgildie Water	Total potable water storage volume	0.2	ML
Mulgildie Water	Volume water lost: potable water	1.5	ML
Mulgildie Water	Water main breaks per 100 km water main	0	per 100 km water main
Mulgildie Water	Water service complaints per 1000 connections	0	per 1000 connections
Mulgildie Water	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections
Mulgildie Water	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections
Mulgildie Water	Average frequency unplanned interruptions: water	0	per 1000 connections
Mulgildie Water	Connected residential properties: water	0.052	000s
Mulgildie Water	Connected non-residential properties: water	0.012	000s
Mulgildie Water	Percent CSS response target met: water incidents	100	%
Mulgildie Water	Water quality complaints per 1000 connections	0	per 1000 connections
Mulgildie Water	Fixed charge: water value	651	\$/annum
Mulgildie Water	Fixed charge: water description		Per Connection Text
Mulgildie Water	Volume water sourced: surface water	NR	ML
Mulgildie Water	Volume water sourced: groundwater	13.5	ML
Mulgildie Water	Maximum daily demand	0.2	ML/day
Mulgildie Water	Volume all water imported: internal and external	NR	ML
Mulgildie Water	Volume all water exported: internal and external	0	ML
Mulgildie Water	Volume potable water produced at a water treatment plant	13.5	ML
Mulgildie Water	Volume potable water supplied: residential	10.2	ML
Mulgildie Water	Volume potable water supplied: non-residential	1.8	ML
Mulgildie Water	Volume water sourced: desalination marine water	NR	ML
Mulgildie Water	Volume water sourced: all	13.5	ML
Mulgildie Water	Water restriction duration: PWCM	254	days
Mulgildie Water	Water restriction duration: Level 1	NR	days
Mulgildie Water	Water restriction duration: Level 2	NR	days
Mulgildie Water	Water restriction duration: Level 3	NR	days
Mulgildie Water	Water restriction duration: Level 4	NR	days
Mulgildie Water	Water restriction duration: Level 5	NR	days
Mulgildie Water	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no
Mulgildie Water	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no
Mulgildie Water	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no
Mulgildie Water	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no
Mulgildie Water	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	yes	yes/no
Mulgildie Water	Months water supply remaining as at 30 June (KPI level)	5	1,2,3,4,5,6
Mulgildie Water	Confidence water demand will be met: next 18 mths	high	high,fair,unsure,low,very low
Mulgildie Water	Confidence water demand will be met: next 5 yrs	high	high,fair,unsure,low,very low
Mulgildie Water	Available contingency supplies	yes	yes/no

POTABLE WATER INDICATORS			
SCHEME	INDICATOR TITLE	VALUE	UNITS
Paradise Dam Water	Number water treatment plants: providing full treatment	1	Count
Paradise Dam Water	Length water mains	0	km
Paradise Dam Water	Capacity of water treatment plants	0.07	ML/day
Paradise Dam Water	Total potable water storage volume	0.05	ML
Paradise Dam Water	Volume water lost: potable water	0.1	ML
Paradise Dam Water	Water main breaks per 100 km water main	0	per 100 km water main
Paradise Dam Water	Water service complaints per 1000 connections	0	per 1000 connections
Paradise Dam Water	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections
Paradise Dam Water	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections
Paradise Dam Water	Average frequency unplanned interruptions: water	0	per 1000 connections
Paradise Dam Water	Connected residential properties: water	0.001	000s
Paradise Dam Water	Connected non-residential properties: water	0.001	000s
Paradise Dam Water	Percent CSS response target met: water incidents	100	%
Paradise Dam Water	Water quality complaints per 1000 connections	0	per 1000 connections
Paradise Dam Water	Fixed charge: water value	NR	\$/annum
Paradise Dam Water	Fixed charge: water description	NR	Text
Paradise Dam Water	Volume water sourced: surface water	0.5	ML
Paradise Dam Water	Volume water sourced: groundwater	NR	ML
Paradise Dam Water	Maximum daily demand	0	ML/day
Paradise Dam Water	Volume all water imported: internal and external	0.9	ML
Paradise Dam Water	Volume all water exported: internal and external	0	ML
Paradise Dam Water	Volume potable water produced at a water treatment plant	0.9	ML
Paradise Dam Water	Volume potable water supplied: residential	0	ML
Paradise Dam Water	Volume potable water supplied: non-residential	0.9	ML
Paradise Dam Water	Volume water sourced: desalination marine water	NR	ML
Paradise Dam Water	Volume water sourced: all	0.9	ML
Paradise Dam Water	Water restriction duration: PWCM	254	days
Paradise Dam Water	Water restriction duration: Level 1	NR	days
Paradise Dam Water	Water restriction duration: Level 2	NR	days
Paradise Dam Water	Water restriction duration: Level 3	NR	days
Paradise Dam Water	Water restriction duration: Level 4	NR	days
Paradise Dam Water	Water restriction duration: Level 5	NR	days
Paradise Dam Water	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no
Paradise Dam Water	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no
Paradise Dam Water	Has water demand forecasts been developed or reviewed in the last 5 yrs?	no	yes/no
Paradise Dam Water	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	no	yes/no
Paradise Dam Water	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	yes	yes/no
Paradise Dam Water	Months water supply remaining as at 30 June (KPI level)	5	1,2,3,4,5,6
Paradise Dam Water	Confidence water demand will be met: next 18 mths	high	high,fair,unsure,low,very low
Paradise Dam Water	Confidence water demand will be met: next 5 yrs	high	high,fair,unsure,low,very low
Paradise Dam Water	Available contingency supplies	yes	yes/no



COUNCIL WIDE INDICATORS			
SCHEME	INDICATOR TITLE	VALUE	UNITS
North Burnett Regional Council WSP-wide	Number water treatment plants: providing full treatment	7	Count
North Burnett Regional Council WSP-wide	Length water mains	135.3	km
North Burnett Regional Council WSP-wide	Sewerage mains breaks/chokes per 100 km sewer main	7.2	per 100 km sewer mains
North Burnett Regional Council WSP-wide	Number sewage treatment plants	7	Count
North Burnett Regional Council WSP-wide	Capacity of water treatment plants	9.14	ML/day
North Burnett Regional Council WSP-wide	Total potable water storage volume	15.323	ML
North Burnett Regional Council WSP-wide	Length sewerage mains and channels	97.2	km
North Burnett Regional Council WSP-wide	Volume water lost: potable water	179.7	ML
North Burnett Regional Council WSP-wide	Water main breaks per 100 km water main	11.8	per 100 km water main
North Burnett Regional Council WSP-wide	Water service complaints per 1000 connections	2.1	per 1000 connections
North Burnett Regional Council WSP-wide	Sewerage service complaints per 1000 connections	2.9	per 1000 connections
North Burnett Regional Council WSP-wide	Water and sewerage billing and account complaints per 1000 connections	2.1	per 1000 connections
North Burnett Regional Council WSP-wide	Water and sewerage complaints (all) per 1000 connections	8.9	per 1000 connections
North Burnett Regional Council WSP-wide	Average frequency unplanned interruptions: water	17.1	per 1000 connections
North Burnett Regional Council WSP-wide	Connected residential properties: water	2.853	000s
North Burnett Regional Council WSP-wide	Connected non-residential properties: water	0.532	000s
North Burnett Regional Council WSP-wide	Connected residential properties: sewerage	2.292	000s
North Burnett Regional Council WSP-wide	Percent CSS response target met: sewerage incidents	100	%
North Burnett Regional Council WSP-wide	Percent CSS response target met: water incidents	100	%
North Burnett Regional Council WSP-wide	Connected non-residential properties: sewerage	0.446	000s
North Burnett Regional Council WSP-wide	Water quality complaints per 1000 connections	2.4	per 1000 connections
North Burnett Regional Council WSP-wide	Revenue: all (NPR) water	3766.3	\$,000
North Burnett Regional Council WSP-wide	Nominal written down replacement cost: fixed sewerage assets	27520.63	\$,000
North Burnett Regional Council WSP-wide	Costs: operating water per connection	851.01	\$/connection
North Burnett Regional Council WSP-wide	Costs: operating sewerage per connection	313.19	\$/connection
North Burnett Regional Council WSP-wide	Capital expenditure: water supply	1083.73	\$,000
North Burnett Regional Council WSP-wide	Capital expenditure: sewerage	700.05	\$,000
North Burnett Regional Council WSP-wide	Revenue: all (NPR) sewerage	2222.673	\$,000
North Burnett Regional Council WSP-wide	Capital works grants: water	0	\$,000
North Burnett Regional Council WSP-wide	Capital works grants: sewerage	0	\$,000
North Burnett Regional Council WSP-wide	Costs: operating water (NPR)	2880.69	\$,000
North Burnett Regional Council WSP-wide	Costs: operating sewerage	857.505	\$,000
North Burnett Regional Council WSP-wide	Costs: any other water	0	\$,000
North Burnett Regional Council WSP-wide	Costs: any other sewerage	0	\$,000
North Burnett Regional Council WSP-wide	Current replacement costs: fixed water assets	71676.98	\$,000
North Burnett Regional Council WSP-wide	Current replacement costs: fixed sewerage assets	56615.85	\$,000
North Burnett Regional Council WSP-wide	Costs: maintenance water	1998.3	\$,000
North Burnett Regional Council WSP-wide	Costs: maintenance sewerage	183.88	\$,000
North Burnett Regional Council WSP-wide	Current cost depreciation: water	1360.62	\$,000
North Burnett Regional Council WSP-wide	Current cost depreciation: sewerage	770.81	\$,000
North Burnett Regional Council WSP-wide	Previous 5 year average annual renewals expenditure: water	559.406	\$,000
North Burnett Regional Council WSP-wide	Previous 5 year average annual renewals expenditure: sewerage	644.81	\$,000
North Burnett Regional Council WSP-wide	Forecast 5 year average annual renewals expenditure: water	2280	\$,000
North Burnett Regional Council WSP-wide	Forecast 5 year average annual renewals expenditure: sewerage	1100	\$,000
North Burnett Regional Council WSP-wide	Nominal written down replacement cost: fixed water assets	37727.77	\$,000
North Burnett Regional Council WSP-wide	Fixed charge: water value	651	\$/annum
North Burnett Regional Council WSP-wide	Fixed charge: sewerage value	634	\$/annum
North Burnett Regional Council WSP-wide	Fixed charge: sewerage description	First Pedestal	Text
North Burnett Regional Council WSP-wide	Annual bill based on 200kL/a: water+sewerage	1675	\$
North Burnett Regional Council WSP-wide	Typical residential bill: water+sewerage	1759.33	\$
North Burnett Regional Council WSP-wide	Fixed charge: water description	Per Connection	Text
North Burnett Regional Council WSP-wide	Volume water sourced: surface water	687.1	ML
North Burnett Regional Council WSP-wide	Volume water sourced: groundwater	522.4	ML
North Burnett Regional Council WSP-wide	Maximum daily demand	7.9	ML/day
North Burnett Regional Council WSP-wide	Volume all water imported: internal and external	1.7	ML
North Burnett Regional Council WSP-wide	Volume all water exported: internal and external	8.8	ML
North Burnett Regional Council WSP-wide	Volume potable water produced at a water treatment plant	1117.9	ML
North Burnett Regional Council WSP-wide	Volume recycled sewage supplied: all	190.5	ML
North Burnett Regional Council WSP-wide	Volume potable water supplied: residential	651.1	ML
North Burnett Regional Council WSP-wide	Volume potable water supplied: non-residential	281.5	ML
North Burnett Regional Council WSP-wide	Volume water sourced: desalination marine water	0	ML
North Burnett Regional Council WSP-wide	Volume water sourced: all	1401.7	ML
North Burnett Regional Council WSP-wide	Volume raw-PT water supplied: residential	NR	ML
North Burnett Regional Council WSP-wide	Volume raw-PT water supplied: non-residential	NR	ML
North Burnett Regional Council WSP-wide	Total full-time equivalent water+sewerage employees	16	FTEs
North Burnett Regional Council WSP-wide	Water restriction duration: PWCM	254	days
North Burnett Regional Council WSP-wide	Water restriction duration: Level 1	111	days
North Burnett Regional Council WSP-wide	Water restriction duration: Level 2	0	days
North Burnett Regional Council WSP-wide	Water restriction duration: Level 3	0	days
North Burnett Regional Council WSP-wide	Water restriction duration: Level 4	0	days
North Burnett Regional Council WSP-wide	Water restriction duration: Level 5	0	days
North Burnett Regional Council WSP-wide	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no
North Burnett Regional Council WSP-wide	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no
North Burnett Regional Council WSP-wide	Has water demand forecasts been developed or reviewed in the last 5 yrs?	no	yes/no
North Burnett Regional Council WSP-wide	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	no	yes/no
North Burnett Regional Council WSP-wide	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	no	yes/no
North Burnett Regional Council WSP-wide	Months water supply remaining as at 30 June (KPI level)	5	1,2,3,4,5,6
North Burnett Regional Council WSP-wide	Confidence water demand will be met: next 18 mths	high	high,fair,unsure,low,very low
North Burnett Regional Council WSP-wide	Confidence water demand will be met: next 5 yrs	fair	high,fair,unsure,low,very low
North Burnett Regional Council WSP-wide	Available contingency supplies	yes	yes/no